

Return address: P.O. Box 2220, 6802 CE ARNHEM, The Netherlands

Unifloor Underlay Systems
Att. Mr. F. Vousten
Arnsbergstraat 4
7418 EZ DEVENTER
The Netherlands

TÜV Rheinland Nederland B.V.
The Netherlands

Postal address:
P.O. Box 2220
6802 CE ARNHEM

Parking and delivery:
Westervoortsedijk 73
6827 AV ARNHEM

www.tuv.com/nl

T +31 88 888 7888

Jaring.de.Wolff@nl.tuv.com

Testreport

Project number: 89210247
Report number: 89210247.39en

Date
26/04/2017

Project number
89210247

Report number
89210247.39en

Phone number client
+31 (0) 570 85 55 33

Fax number client
+31 (0) 570 85 55 44

Received:

A floor covering underlay system, marked as: **“Redupax 9 mm”**;
TÜV-reference: MT17-117021.38

Article
Redupax 9 mm

Sampling procedure:

The samples are selected by the applicant. The test house has had no influence on the sampling procedure.

Appendix
- none -

The samples have been received on 12/01/2017.

Order:

Determination of compressive strength according EN 826:2013 and CEN/TS 16354:2013.

Results:

See page three.

Appendix:

None.

TRN applies General Terms & Conditions which are filed at the office of the Clerk for civil affairs at the Court in Zutphen (the Netherlands) under number 35/2010, dated November 17th 2010.

PRODUCT IDENTIFICATION

Applicant : Unifloor Underlay Systems
Product name : **Redupax 9 mm***
** Applicant's declaration*

Date
26/04/2017

Project number
89210247

Report number
89210247.39en

Article
Redupax 9 mm

Page
2/3



Figure 1. Picture of the received sample

Date
26/04/2017

Project number
89210247

Report number
89210247.39en

Article
Redupax 9 mm

Page
3/3

TEST RESULTS

Determination of compression behaviour

Method EN 826:2013 and CEN/TS 16354:2013

Conditioning : 23±2 °C and 50±5 %
Date of testing : 10/04/2017
Dimensions of the tested sample : Square, 200 x 200 mm
Number of tested samples : 5
Surface treatment : none


Test results

Compressive strength in kPa at 0.5 mm strain.

| Test no. | Thickness (mm) | Compressive strength (kPa) |
|-------------------|----------------|----------------------------|
| Test no. 1 | 9.03 | 397 |
| Test no. 2 | 9.05 | 374 |
| Test no. 3 | 8.99 | 368 |
| Test no. 4 | 9.09 | 403 |
| Test no. 5 | 8.66 | 388 |
| Mean value | 8.96 | 386 |

Table 1. Test results.

Author:
Mr. J. de Wolff



Review:
Mr. M.A. van de Vlekkert



All rights reserved.

No part of this report may be reproduced, provided to and/or examined by third parties, and/or published by print, photoprint, microfilm, in electronic form or any other means without the explicit previous written consent of TÜV Rheinland Nederland B.V. The results are based upon the samples received and have not to be representative for the total production. TÜV Rheinland Nederland B.V. had no influence on the sampling.

In case this report was drafted within the context of an assignment to TÜV Rheinland Nederland B.V., the rights and obligations of contracting parties are subject to the General Terms & Conditions for Advisory, Research and Certification assignments to TÜV Rheinland Nederland B.V. and/or the relevant agreement concluded between the contracting parties.

© 2010 TÜV Rheinland Nederland B.V.

(end of report)